

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1328 – CPR – 0518

In compliance with Regulation (EU) no. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FIRE DETECTION AND FIRE ALARM SYSTEMS: VISUAL ALARM DEVICE AND SOUNDER

Intended use	Type Reference
Fire detection and fire alarm systems installed in and around buildings	FC-LUX23

Technical characteristics:
<p>Sounder: Type A (Indoor use)</p> <p>Visual Alarm Device: Type A / Category W-4,6-9,1 / Category O - Max mounting height: 4,6m and maximum room base dimension: 9,1mx9,9m (equipment placed in the center of the 9,1m room side)</p>

produced by

TYCO Fire & Security GmbH

Victor von Bruns - Strasse 21, 8212 Neuhausen am Rheinfall, Switzerland

and produced in the manufacturing plant(s)

Identification code: ALA.923

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-23:2010

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

under system 1 are applied and that
the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2015-10-28 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Almada, 28th October 2015



Francisco Barroca
General Manager